

OKEFENOKE RURAL ELECTRIC MEMBERSHIP CORPORATION

POLICY NO. 417

ELECTRIC METERING EQUIPMENT

I. OBJECTIVE:

To establish policy for the application and installation of electric metering equipment.

II. CONTENT:

All meter bases should be installed on an exterior surface or pole as nearly as possible at eye level. Upon receipt of the application for service, an authorized representative of the Cooperative shall approve the location of the meter center in a mutually agreeable location.

All meter installations shall be made in accordance with the National Electric Code and all other applicable codes.

All meters shall be placed ahead of all switches and protective devices unless otherwise agreed to by the Cooperative.

For large single-phase installations of over 200 amperes and for three-phase installations, the Cooperative shall specify the type of metering equipment required before installation of same.

In case of new line construction requiring the relocation of the meter, said relocation shall be at the expense of the Cooperative.

The Cooperative will normally furnish a single meter for each class of service at the point of connection to the member's premises. Any member desiring service at two or more separately metered points of connection to the distribution system shall be billed separately at each such point and the metered energy consumption of such members shall not be combined for billing purposes.

Current transformer metering will be used when the magnitude of the load to be served warrants installation of such equipment. However, if requested by member simply for member's convenience, member shall pay additional costs associated with current transformer metering installation.

III. APPLICABILITY:

This policy applies to all members and services of the Cooperative.

IV. RESPONSIBILITY:

The General Manager or his designee shall be responsible for carrying out the provisions of this policy.

Date Adopted: April 26, 1994

Effective Date: July 1, 1994