



OKEFENOKE RURAL ELECTRIC MEMBERSHIP CORPORATION MINIMUM REQUIREMENTS FOR OVERHEAD ELECTRIC SERVICE.

ALL SERVICE EQUIPMENT SHALL BE FURNISHED, INSTALLED, AND MAINTAINED BY CUSTOMER/ELECTRICIAN PER THE REQUIREMENTS SET BY NATIONAL ELECTRIC CODE (NEC) AND/OR LOCAL CODES.

METER BASE- SHALL BE COMPATIBLE FOR USE WITH OVERHEAD SERVICE. METER BASE SHALL BE EFFECTIVELY GROUNDED.

GROUNDS- #4 SOLID COPPER CONDUCTOR AND TWO (2) 8' GROUNDING RODS, SIX (6) FEET APART. (CHECK LOCAL CODES). ALL-IN-ONE OR COMBINATION SERVICE EQUIPMENT MEETING CODE SPECIFICATIONS ARE ACCEPTABLE.

CONDUITS/RISER- RIGID, GALVANIZED METAL. MAST SHOULD NOT EXCEED 36' ABOVE ROOF. SERVICE CONDUCTORS SHALL HAVE NO LESS THAN 18" OF VERTICAL CLEARANCE ABOVE ROOF WITHIN 6' RADIUS OF SERVICE MAST, OR NO LESS THAN 36' VERTICAL CLEARANCE ABOVE ROOF OUTSIDE 6' RADIUS OF SERVICE MAST. CONDUCTORS (SIZE AS REQUIRED) WILL HAVE 24" TAILS TO FORM DRIP LOOP. (CHECK LOCAL CODES).

ELECTRIC SERVICE EQUIPMENT SHALL BE PLACED IN A LOCATION AGREEABLE TO DREMC.

DREMC WILL FURNISH/INSTALL SERVICE SUPPLY CONDUCTORS AND METER. SPECIFICATIONS ON THIS PAGE REPRESENT DREMC MINIMUM STANDARDS. LOCAL CODES MAY CALL FOR ADDITIONAL OR MORE STRINGENT REQUIREMENTS. THE DOWNER/ELECTRICIAN MUST ENSURE COMPLIANCE WITH ALL APPLICABLE CODES GOVERNING ELECTRICAL SERVICE.

OKEFENOKE RURAL ELECTRIC MEMBERSHIP CORPORATION			
NAHUNTA, GEORGIA			
CONSTRUCTION STANDARDS			
OVERHEAD METER BASE INSTALLATION			
DWN.	BB	DATE: 05/18/2023	DWG. NO.
CKD.	MBM/WSD	APPD.	WSD
SCALE: N.T.S. 584-6233			
DATE	REVISION	DATE	REVISION
05/18/23	BB		
584B_24			© 04/05